


**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.**

No. 453Date : 23/07/2025

It is certified that an inspection team headed by MR. RAMESH
(Name of Officers
with designation) from श. अभियंता नगर निगम कोटा दक्षिण (Name of
Department/Office) inspected the SHIV JYOTTI CONVENT SR. SEC. SCHOOL,
RATHKANKARA, RAWATBHATA ROAD, KOTA (Name & Address of
the School) on 16/07/2025 and found that the SHIV JYOTTI CONVENT
SR. SEC. SCHOOL, RATHKANKARA (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of 01 year.Signature with Seal : Name : स्वास्थ्य निरीक्षकDesignation : नगर निगम कोटा दक्षिण

To

SHIV JYOTTI CONVENT SR. SEC.
SCHOOL, RATHKANKARA
RAWATBHATA ROAD, KOTA (Raj.)

(Name & Address of the Institution)



OFFICE OF THE SENIOR CHEMIST
REGIONAL LABORATORY, PHED, KOTA, RAJASTHAN
 PHED Campus, AKELGARH KOTA-324010



Test Report
(CHEMICAL & BACTERIOLOGICAL EXAMINATION OF WATER)

Disp. No. : **SS2**

Dated : **12/8/25**

Issued to:

Principal

**Shiv Jyoti Convent School Rathkankara, Rawatbhata Road
 Kota**

District: **Kota**
 Block/City: **Kota**

Sample No. Collected by Lab

Ref ID	12			Sample Code No.	PC-78 PB-73
Reference : Letter No.		NM		Source :	R.O.
Reference Date:		06.08.25		Source Location :	Shiv Jyoti Convent School Rathkankara
Date of Receipt :		06.08.25		Habitation/Ward No. :	-
Sample ID	20				
Name of Sample Collector:		Mukesh Jangid		Village/Colony/Nagar :	Kota
Designation of Sample Collector:		0		Gram Panchayat/City Area :	-
Latitude of Location				Date of Collection :	06.08.25
Longitude of Location				Start Date of Examination :	06.08.25
Elevation of Location				End Date of Examination :	12.08.25
Test Parameters		IS-10500:2012(RA 2018)		Sample Report No.	
		Requirement (Acceptable Limit)	Permissible limit in the absence of alternative sources	References Method:	Test Values
1	pH At Temp. 25 ⁰ C	6.5 to 8.5	No relaxation	[IS 3025, P-11], 2022	7.52
2	Turbidity	1.0	5.0	-	0.50
3	Taste	Not Defined	Not Defined	-	-
4	Odour	Unobjectionable	Unobjectionable	-	-
5	Total Alkalinity (as CaCO ₃) mg/l	200	600	[IS 3025, P-23], 1986 (RA2023)	70
6	Total Hardness (as CaCO ₃) mg/l	200	600	[IS 3025, P-21], 2009 (RA 2023)	80
7	Calcium (as Ca ⁺⁺) mg/l	75	200	[IS 3025, P-40], 1991 (RA 2024)	-
8	Magnesium (as Mg ⁺⁺) mg/l	30	100	[IS 3025, P-46], 1994 (RA 2023)	-
9	Chloride (as Cl ⁻) mg/l	250	1000	[IS 3025, P-32], 1988 (RA 2019)	30
10	Nitrates (as NO ₃ ⁻) mg/l	45	No relaxation	[APHA, Ed24, 4500-B] NO3: 2022	4
11	Fluoride (as F ⁻) mg/l	1.0	1.5	[IS 3025, P-60], 2008 (RA 2023)	0.113
12	Total Dissolved Solids (TDS) mg/l At 180 ⁰ C	500	2000	[IS 3025 P-16]:1983 (RA 2023) [APHA, Ed24, 2510-B] Cond.2022	155
11	Total Coliform (MPN/100ml)	Nil	Nil	-	NIL

(*ADL= Above detection limit; BDL= Below detection limit)

**REPORT IS NOT VALID FOR
 JUDICIAL AND COMMERCIAL
 PURPOSE**

Authorized Signatory

 Senior Chemist
 PHED Reg.Lab. Kota

NOTE:

- 1 This test report shall not be reproduce except in full, unless permission for the reproduction of an approved abstract has been obtained from the Senior Chemist, REGIONAL LABORATORY PHED, KOTA (Rajasthan).
- 2 This test report relates only to the samples/items submitted to the laboratory for test.
- 3 This report is not valid for legal cases/legal purposes.
- 4 Sample will be preserved only for 15 days from date of receipt.
- 5 Measurement of uncertainty and standard methods will be provided to customer on demand.

Telephone : 0744-2470946

E-mail: lab.kot.phed@rajasthan.gov.in

-----End of the Report-----